

(AN ISO/IEC-17025:2005/Certified/NABL Accredited Lab)

Report No-MCT/OTH/18/320/2


Date: -20.03.2018

TEST REPORT

1.	NAME & ADDRESS OF CUSTOMER:	Shri Balaji Metacast Pvt. Ltd. Newai, (Tonk)
2.	Your Ref. / letter no. & date :	LETTER No- DATED: - 16.03.2018
3.	Name of Agency :	--
4.	Name of work: (as per customer letter)	Testing of Stone Dust Sample for
5.	Date of Sample Received:	16.03.2018
6.	Sample Description	sample received in good condition, (Sample Supplied by Customer)
7.	Date of Testing	20.03.2018

RESULTS:**WORK SHEET FOR TESTING OF STONE DUST SAMPLE**

S. No	IS Sieve Designation	Test Method	Result	Standards as per IS Passing (Zone-II)
1.	Sieve Analysis	IS 2386 (Part.- I) 1963, Reaff. 2016	% Passing	
(i)	10.00 MM		100.0	100
(ii)	4.75 MM		99.71	90-100
(iii)	2.36 MM		99.0	75-100
(iv)	1.18 MM		78.6	55-90
(v)	600 MIC		45.2	35-59
(vi)	300 MIC		22.0	8-30
(vii)	150 MIC		5.6	0-10 0-20*
2.	Silt content		2.0 %	Max. 8% (as per CPWD Specification)



Pratiksha
Authorized Signatory
Designation: TM/QM

Note:

- ▶ Results related only to the sample (s) under test in as received condition and applicable parameter (s) Endorsement of product is neither inferred nor implied
- ▶ This Test Report Shall Not reproduced wholly or in part and can not be used as evidence in the court of law without written approval of M/s MCT Jaipur..
- ▶ Balance Samples, if any shall be discarded after one month from the date of issue of report.
- ▶ Total liability of our lab is limited to the invoiced amount.
- ▶ Sample(s) was not drawn by M/sMCT, Jaipur unless mentioned otherwise.

End of Report

Page 1 of 1